



INSTITUTO
SUPERIOR
TÉCNICO

Title



FLOXCOM – LOW NO_x FLOX COMBUSTOR FOR HIGH EFFICIENCY GAS TURBINES

WP4 – Fuel Injection System Development

*M. J. Melo, J. M. M. Sousa, M. Costa
and P. Coelho*

Mechanical Engineering Department
Instituto Superior Técnico/Technical University of Lisbon
Av. Rovisco Pais. 1049-001 Lisboa. Portugal



WP4 – Main Tasks



- Task 4.1** Design and construction of the wind tunnel and different sets of water atomisers and air injectors;
- Task 4.2** Construction of the combustor model;
- Task 4.3** Numerical simulation of the combustor model;
- Task 4.4** Experimental investigation of the fuel supply system;
- Task 4.5** Testing of the combustor model.



Task 4.5 Testing of the Combustor Model



Experimental study of the combustion model at atmospheric pressure:

Under non reacting conditions:

mean and turbulent velocities

Under reacting conditions:



mean gas species concentration

(O_2 , CO_2 , CO , NO_x , HC).





INSTITUTO
SUPERIOR
TÉCNICO

Geometry of the Combustor: Original Model



Experimental Set-up





INSTITUTO
SUPERIOR
TÉCNICO

Study Under Non-Reacting Conditions



Variables considered:

**flow rate of air 1;
preheating of air 1.**


Data include:


mean and turbulent velocities.



INSTITUTO
SUPERIOR
TÉCNICO

LDA Measurement System





Test Conditions

Test Condition	Air 1			Fuel (Air*)		
	Flow rate [kg/s]	Temperature [K]	Pressure [mbar]	Flow rate [kg/s]	Temperature [K]	Pressure [bar]
1	0.120	293	220	0.00317	293	2.4
2	0.120	330	230	0.00317	293	2.4
3	0.095	330	110	0.00317	293	2.4
4	0.070	330	40	0.00317	293	2.4

*fuel simulation




INSTITUTO
SUPERIOR
TÉCNICO

Typical Result for the Mean Flow Structure



Test condition 2 - Air 1: 0.12 kg/s






INSTITUTO
SUPERIOR
TÉCNICO

Typical Result for the Turbulence Kinetic Energy



Test condition 2 - Air 1: 0.12 kg/s






INSTITUTO
SUPERIOR
TÉCNICO


Effect of the Air 1 Flow Rate on the Mean Flow Structure




Test condition 4
Air 1: 0.07 kg/s




Test condition 3
Air 1: 0.095 kg/s



Test condition 2
Air 1: 0.12 kg/s




Effect of the Air 1 Flow Rate on the Mean Flow Structure (cont.)




Effect of the Air 1 Flow Rate on the Turbulence Kinetic Energy Contours




Test condition 4
Air 1: 0.07 kg/s



Test condition 3
Air 1: 0.095 kg/s




Test condition 2
Air 1: 0.12 kg/s




Effect of the Air 1 Inlet Temperature on the Mean Flow Structure



Test condition 1
Temperature of Air 1: 293 K



Test condition 2
Temperature of Air 1: 330 K





Non-Reacting Conditions: Conclusions





A common feature to all test conditions is the establishment of a large recirculation zone.

Mean and turbulent velocities increase within the recirculation zone as the flow rate of Air 1 increases.

Near the combustor outlet the mean and turbulent velocities are higher for the intermediate Air 1 flow rate tested.

Effect of the inlet temperature of Air 1 on the flow field is marginal.



Geometry of the Combustor: Original Model






INSTITUTO
SUPERIOR
TÉCNICO

Geometry of the Combustor: Original Model




Geometry of the Combustor: Modified Model A





INSTITUTO
SUPERIOR
TÉCNICO


Geometry of the Combustor: Modified Model A





INSTITUTO
SUPERIOR
TÉCNICO



Geometry of the Combustor: Modified Model B





INSTITUTO
SUPERIOR
TÉCNICO


Geometry of the Combustor: Modified Model B





INSTITUTO
SUPERIOR
TÉCNICO

Combustion Measurement System









Test Conditions







Test Condition	Air 1		Methane	Equivalence ratio, Φ
	Flow rate [kg/s]	Temperature [K]	Flow rate [kg/s]	
Original Model Configuration				
1	0.012	380	7.79E-05	0.10
2		387	1.56E-04	0.22
3		387	2.39E-04	0.34
4	0.023	361	1.56E-04	0.12
5		361	2.39E-04	0.18
6	0.031	369	1.56E-04	0.08
7		368	2.39E-04	0.013
8		368	3.27E-04	0.18
9	0.038	368	1.56E-04	0.07
10		368	2.39E-04	0.11
11		368	3.27E-04	0.15
12		369	4.18E-04	0.19

Test Condition	Air 1		Methane	Equivalence ratio, Φ
	Flow rate [kg/s]	Temperature [K]	Flow rate [kg/s]	
Modified Model Configuration A				
1	0.012	378	1.17E-04	0.17
2		378	1.56E-04	0.22
3		384	2.39E-04	0.34
4	0.020	403	1.56E-04	0.13
5		402	2.39E-04	0.20
6		403	3.27E-04	0.28
7		405	4.18E-04	0.35
8	0.027	409	2.39E-04	0.15
9		407	3.27E-04	0.20
10		407	4.18E-04	0.27
11		409	5.12E-04	0.33
12	0.035	411	3.27E-04	0.16
13		411	4.18E-04	0.21
14		414	5.12E-04	0.25
15		417	6.22E-04	0.30

Flue-Gas Data for the Original Model Configuration



Flue-Gas Data for the Modified Model A Configuration





Reacting Conditions: Conclusions



Combustion performance is higher for both lower values of thermal input and equivalence ratio.


Effect of the air inlet configuration on both combustor performance and pollutant emissions is marginal.

NO_x emissions are very low regardless of the combustor operating conditions.



INSTITUTO
SUPERIOR
TÉCNICO

3.9 kW, $\Phi = 0.10$






INSTITUTO
SUPERIOR
TÉCNICO



7.8 kW, $\Phi = 0.22$



12.0 kW, $\Phi = 0.34$





INSTITUTO
SUPERIOR
TÉCNICO



7.8 kW, $\Phi = 0.12$





INSTITUTO
SUPERIOR
TÉCNICO



12.0 kW, $\Phi = 0.18$





INSTITUTO
SUPERIOR
TÉCNICO


7.8 kW, $\Phi = 0.08$





INSTITUTO
SUPERIOR
TÉCNICO

12.0 kW, $\Phi = 0.13$





INSTITUTO
SUPERIOR
TÉCNICO

16.3 kW, $\Phi = 0.18$





INSTITUTO
SUPERIOR
TÉCNICO

16.3 kW, $\Phi = 0.18$






INSTITUTO
SUPERIOR
TÉCNICO




5.8 kW, $\Phi = 0.17$





INSTITUTO
SUPERIOR
TÉCNICO

7.8 kW, $\Phi = 0.22$





INSTITUTO
SUPERIOR
TÉCNICO


12.0 kW, $\Phi = 0.34$





INSTITUTO
SUPERIOR
TÉCNICO


7.8 kW, $\Phi = 0.13$





INSTITUTO
SUPERIOR
TÉCNICO


12.0 kW, $\Phi = 0.20$





INSTITUTO
SUPERIOR
TÉCNICO


16.3 kW, $\Phi = 0.28$





INSTITUTO
SUPERIOR
TÉCNICO


25.6 kW, $\Phi = 0.33$





INSTITUTO
SUPERIOR
TÉCNICO


12.0 kW, $\Phi = 0.15$





INSTITUTO
SUPERIOR
TÉCNICO



16.3 kW, $\Phi = 0.20$





INSTITUTO
SUPERIOR
TÉCNICO

20.9 kW, $\Phi = 0.27$





INSTITUTO
SUPERIOR
TÉCNICO

25.6 kW, $\Phi = 0.33$






INSTITUTO
SUPERIOR
TÉCNICO





16.3 kW, $\Phi = 0.16$





INSTITUTO
SUPERIOR
TÉCNICO


20.9 kW, $\Phi = 0.21$





INSTITUTO
SUPERIOR
TÉCNICO

25.6 kW, $\Phi = 0.25$





INSTITUTO
SUPERIOR
TÉCNICO

30.1 kW, $\Phi = 0.30$

